



of Florida, LLC

9/3/2013

Attn.: Drinking Water Compliance
DEP – Central District
3319 Maguire Blvd., Suite 232
Orlando, FL 32803-3767

RE: Colina Bay / PWS #3354969

Please find the August 2013 Monthly Operating Report for the above referenced Water Treatment Facility.

If you have any questions concerning these reports, please don't hesitate to call Dennis Muldoon at (727) 863-5161, ext. 117. Dennis.M@ug-fl.com

Sincerely,

Dennis Muldoon

Dennis Muldoon
Operations & Compliance Manager



MONTHLY OPERATION REPORT FOR PWS'S TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

See page 4 for instructions

I. General Information for the Month/year of: August 2013

A. Public Water System (PWS) Information

PWS Name: Colina Bay PWS Identification Number: 3354969

PWS Type: XX Community Non-Transient Non-Community Transient Non-Community Consecutive

Number of Service Connections at End of Month: 28 Total Population Served at End of Month: 70

PWS Owner: Great Communities

Contact Person: Matt Jordan Contact Person's Title: Community Manager

Contact Person's Mailing Address: City: Tampa State: Florida Zip Code: 33613

Contact Person's Telephone Number: 407-647-2622 Contact Person's Fax Number:

Contact Person's E-Mail Address:

Plant Name: Colina Bay Plant Telephone Number: 727-863-5161 State: Florida Zip Code: 34756

Plant Address: Caravaggio Loop City: Monte Verde

Type of Water Treated by Plant: XX Raw Ground Water Purchased Finished Water

Permitted Maximum Day Operating Capacity of Plant, gallons per day: 115,000gpd.

Plant Category (per subsection 62-699.310(4), F.A.C.): V Plant Class (per subsection 62-699.310(4), F.A.C.): D

Operator Name	License Class	Days/Week
Dennis Muldoon	C	2 Days/Week
Stan Pingot	C	2 Days/Week
Darrell Hicks	C	2 Days/Week

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in Part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates, and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date: Dennis Muldoon 9.3.13 Dennis Muldoon / Lead Operator License Number: C-5980

Printed or Typed Name

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 3354969

Plant Name: Colinas Bay

III. Data: Data for the Month Year of:

August 2013

Means of Achieving Four-Log Virus Inactivation/Removal: * XX Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Ultraviolet Radiation Other (Describe):

XX Free Chlorine

Combined Chlorine (Chloramines)

Chlorine Dioxide

Type of Disinfectant Residual Maintained in Distribution System:	XX Free Chlorine		Chlorine Dioxide		Combined Chlorine (Chloramines)		Chlorine Dioxide	
	24 Hr. Free Chlorine Residual (mg/L)	7 Day Average Free Chlorine Residual (mg/L)	24 Hr. Chlorine Dioxide Residual (mg/L)	7 Day Average Chlorine Dioxide Residual (mg/L)	24 Hr. Combined Chlorine Residual (mg/L)	7 Day Average Combined Chlorine Residual (mg/L)	24 Hr. Chlorine Dioxide Residual (mg/L)	7 Day Average Chlorine Dioxide Residual (mg/L)
X	24	161,000						
	24	166,000	0.34					0.29
	24	188,000						
	24	188,000						
X	24	188,000	0.35					0.28
	24	179,500						
X	24	179,500	0.39					0.23
	24	196,000						
X	24	196,000	0.36					0.26
	24	233,300						
X	24	233,300	0.62					0.35
	24	221,500						
X	24	221,500	0.48					0.23
	24	212,000						
X	24	212,000	0.29					0.25
	24	79,600						
	24	79,600						
X	24	79,600	0.68					0.33
	24	227,500						
X	24	227,500	0.30					0.28
	24	239,500						
X	24	239,500	0.33					0.23
	24	725,000						
	24	725,000						
X	24	725,000	0.60					0.23
	24	156,500						
X	24	156,500	0.48					0.23
	24	212,500						
X	24	212,500	0.94					0.27
	24	222,500						
	24	7,517,200						
	24	242,490						
	24	725,000						