



MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

See Page 4 for instructions

I. General Information for the Month/Year of: January 2021

A. Public Water System (PWS) Information

PWS Name: Colina Recovery Inc		PWS Identification Number: 335-4969	
PWS Type: Community <input checked="" type="checkbox"/>	NonTransient <input type="checkbox"/>	NonCommunity <input type="checkbox"/>	Consecutive
Number of Service Connections at End of Month: 75		Total Population Served at End of Month: 175	
PWS Owner: Colina Bay Homeowners Assoc			
Contact Person: Ana Orge		Contact Person's Title: President	
Contact Person's Mailing Address: 882 Jackson Avenue		City: Winter Park	State: FL Zip Code: 32789
Contact Person's Telephone Number: 954-448-6743		Contact Person's Fax Number:	
Contact Person's Email Address: Ana.ColinaBayHOA@gmail.com			

B. Water Treatment Plant Information

Plant Name: Colina Recovery Inc		Plant Telephone Number:		
Plant Address: Caravaggio Loop		City: Montverde	State: FL Zip Code: 34756	
Type of water treated by Plant: <input checked="" type="checkbox"/> Raw Ground <input checked="" type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 115000				
Plant Category (per subsection 62-699.310(4), F.A.C.): D		Plant Class (per subsection 62-699.310(4), F.A.C.): V		
Licensed Operators:	Name:	License Class	License Number	Day(s)/Shift(s) Worked
Lead/Chief Operators:	Powell, Trevor	C	17573	
Other Operators:	Foster, Nathan (Grant)	C	17629	

II. Certification by Lead/Chief Operator

I the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in Part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standard referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rate, and (2) if applicable, appropriate treatment process performance records. Further more, I agree to provide these additional operations records to the PWS owner so that the PWS owner can retain them, together with copies of this report, at a convenient location for the last ten years.

<i>Powell, Trevor</i>	2/2/2021	Powell, Trevor	C 17573
Signature and Date		Printed or Typed Name	License Number

PWS Identification Number: 335-4969

Plant Name: Colina Recovery Inc.

WTP

III. Daily Data for the Month/Year of: January 2021

Means of Achieving Four-Log Virus Inactivation/Removal * Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

UltraViolet Radiation Other (Discribe)

Type of Disinfectant Residual Maintained in Distribution System: X Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or visited by operator Place "X"	Hours Plant in Operation	Net Quantity of Finished Water Produced, gal	CT Calculations, or UV Dose, to Demonstrate Four-Log Virus Inactivation, if Applicable*									Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations						UV Dose					
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp. of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24	37,667		1.20									0.70	
2		24	37,667												
3		24	37,667												
4	X	24	10,500		1.10									0.70	
5		24	10,500												
6	X	24	13,500		1.30									0.90	
7		24	13,500												
8	X	24	18,333		1.20									0.90	
9		24	18,333												
10		24	18,333												
11	X	24	15,500		1.20									0.90	
12		24	15,500												
13	X	24	15,000		1.30									0.90	
14		24	15,000												
15	X	24	46,000		1.20									0.80	
16		24	46,000												
17		24	46,000												
18	X	24	14,000		1.00									0.60	
19		24	14,000												
20	X	24	24,000		1.00									0.70	
21		24	24,000												
22	X	24	30,667		1.10									0.70	
23		24	30,667												
24		24	30,667												
25	X	24	32,500		1.10									0.80	
26		24	32,500												
27	X	24	19,500		1.30									0.90	
28		24	19,500												
29	X	24	30,333		1.30									0.90	
30		24	30,333												
31		24	30,333												
Total			778,000												
Average			25,097												
Maximum			46,000												