

**DRINKING WATER MICROBIAL SAMPLE COLLECTION & LABORATORY REPORTING FORMAT**

- 6681 Southpoint Pkwy. • Jacksonville, FL 32216 • 904.363.9350 • Fax 904.363.9354 • E82574
- 4965 SW 41st Blvd • Gainesville, FL 32608 • 352.377.2349 • Fax 352.395.6639 • E82001
- 10200 USA Today Way • Miramar, FL 33025 • 954.889.2288 • Fax 954.889.2281 • E82535
- 9610 Princess Palm Ave. • Tampa, FL 33619 • 813.630.9616 • Fax 813.630.4327 • E84589
- 380 Northlake Blvd., Suite 1048 • Altamonte Springs, FL 32701 • 407.937.1594 • E53076
- 2639 N. Monroe St., Suite D, Tallahassee, FL 32303 • 850.219.6274 • Fax 850.219.6275 • E811095
- 13100 Westlinks Terrace, Unit 10, Fort Myers, FL 33913 • 239-674-8130 • Fax 239-674-8128 • E84492



**Advanced Environmental Laboratories, Inc.**

Lab Receipt Date & Time: 11/8/20 16:30  
 Analysis Date & Time: 11/8/20 18:11  
 Sample Acceptance Criteria:  
 Sample Preservation:  On Ice  Not On Ice  4 °C  
 Disinfectant Check:  Not Detected   
 This Sample does not meet the following NELAC requirements:

Report Number: \_\_\_\_\_ Sub-Contract Lab ID: \_\_\_\_\_

Analysis Requested: (check all that apply)

- Total Coliform/E. coli  Total Coliform/Fecal  Enterococci  Coliphage  HPC  Other: \_\_\_\_\_

Public Water System (PWS) Name: Colina BAY HOA

PWS I.D.: 335-4969

PWS Address: Carravaggio Loop

City: Montverde FL.

PWS or PWS Owner's Phone #: 727-848-8292

Fax #: 727-848-7701

Collector: Trevor Howell

Collector's Phone #: \_\_\_\_\_

Type of Supply: (check only one)

- Community Water System  Non-Transient Non-community Water System  Transient Non-community Water System  
 Limited Use System  Bottled Water  Private Well  Swimming Pool  Other: \_\_\_\_\_

Reason for Sampling: (check all that apply)

- Distribution Routine  Distribution Repeat  Raw (triggered or assessment)  Raw (triggered or assessment) additional  Well Survey  
 Clearance  Replacement (also check type of sample being replaced)  Boil Water Notice  Other: \_\_\_\_\_

Sample Collection Date: 10-8-20

DCN#: AD-D045

Effective 01/95, Printable Revision 4/1/17

Sample #	Sample Point (Location or Specific Address)	Sample Collection Time (24 hr clock)	Sample Type	Disinfectant Residual (mg/L)	pH	Analysis Method(s) <u>42233</u>				
						Non-Coliform	Total Coliform	Fecal (E. coli), Enterococci, or Coliphage	Data Qualifier	Lab Sample #
CB1	Raw Well	710	R	0		A	A			1
CB2	14808 Borromini	720	D	1.0		A	A			2

Average of disinfectant residuals for distribution routine & repeat samples.  Free chlorine or  Total chlorine (check one).

1.0

Disinfectant Residual Analysis Method:

- DPD Colorimetric  Other: \_\_\_\_\_

Person performing disinfectant analysis is (Check one of below):

- A certified operator (# C17573)  
 Supervised by certified operator (# \_\_\_\_\_)  
 Employed by a certified lab  Employed by DEP or DOH  
 Authorized representative of supplier of water

(INSERT NAME AND MAILING ADDRESS OF PERSON TO RECEIVE REPORT)

US WATER  
4939 Cross Bayou Blvd  
New Port Richey, FL.

Unless otherwise noted, all tests are performed in accordance with NELAC standards, and the results relate only to the samples.

Date and time PWS notified by lab of positive results: \_\_\_\_\_

Date and time DEP/DOH notified by lab of positive results: \_\_\_\_\_

Lab Signature: [Signature]

Title: DM

Date & Time Report issued: \_\_\_\_\_

Satisfactory ; DEP/DOH USE ONLY

**REVIEWED**  
 By Carolynn Turneur at 8:37 am, Nov 13, 2020  
 DEP/DOH Reviewing Official: \_\_\_\_\_

- Indicate the sample type for each sample collected. Sample type codes are: D = Distribution (routine compliance), C = Repeat/Check, R = Raw, N = Entry Point to Distribution, P = Plant Tap, S = Special (clearance, etc.).
  - Lab certification number for the listed method is included at top with the laboratory address.
  - Please circle appropriate selection.
  - Defined in Florida Administrative Code Rule 62-160, Table 1.
  - Complete for community & non-transient non-community systems serving populations up to and including 4,900. Do not include raw or plant samples in the average.
- Results Key: A = Coliforms are absent; P = Coliforms are present; C = confluent growth; TNTC = too numerous to count (62-550.730 Reporting Format).

Relinquish By: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_

Received By: [Signature]

Date: 11/8/20 Time: 14:00